



Prof (Dr) Vadivukkarasi P
 Prof-cum-Principal
 Ph : 82838-24167
 E-mail : acn@awesindia.edu.in

Army College of Nursing
 Deep Nagar
 Jalandhar Cantt-144005

MAINTENANCE RECORD – GENERATOR SETS

#	Gen set Sino	Service to	Next Serv	New items / Qty	Next due	Cost	E/S	Remarks
1	4H 5066/1200/86 100 KVA JC/107/100/84/7752X	↓ 50 hrs or 6 month	↓ 28 Nov 2023	Eng oil - 75 ltr Coolant - up to level Air cleaner element - cleaned oil filter lubricant - 06 pcs	↓ MAY - 2024	mf	Blf	AMT - 27665/-
2	F 6-3423/1200/02 180 KVA	↓ 50 hrs or 6 month	↓ 28 Nov 2023	oil filter - 06 pcs Sea filter - 01 pcs Fuel filter kit - 02 pcs Tank cleaning - 03 task level ppe - 03	↓ MAY - 2024	mf	Blf	AMT - 1652/-
3	F 6/3423/1200/03 180 KVA	↓ 50 hrs or 6 month	↓ 28 Nov 2023	Eng oil - 75 ltr coolant - up to level Air cleaner - cleaned oil filter - 06 pcs Fuel filter kit - 02 level ppe / tank ppe Raising & sea element - 02 fuel ppe - 02 pcs clamp small - 06 pcs charger -	↓ MAY - 2025	mf		AMT - 30215/-

Col (Retd)
 Registrar
 Army College of Nursing
 Jalandhar Cantt

Principal
 Army College of Nursing
 Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
 Prof-cum-Principal
 Ph : 82838-24167
 E-mail : acn@awesindia.edu.in

Army College of Nursing
 Deep Nagar
 Jalandhar Cantt-144005

MAINTENANCE RECORD – AIR CONDITIONERS

SNO	AC SNO	Date of Service	Repair Service	Medicine	RTS	Remarks
<u>MP hall VAV</u>						
1	0007773	Mar	Service & Gas filling			
2	0008432	2024	"			
3	0008372	"	"			
4	0007262	"	"			
<u>Library Aikin</u>						
1	0012316	MAR	Service			
2	0012719	2024	"			
3	0012315	"	"			
4	0012325	"	"			
5	0012313	"	"			
6	0012310	"	"			
7	0012715	"	"			
8	0012354	"	"			
9	0012720	"	"			
10	0012694	"	"			
11	0012701	"	"			
12	0012701	"	"			
<u>2nd New Ace filling</u>						
<u>Camp Lab Dakin</u>						
1	0024597	Mar	Service			
2	0024603	2024	"			
3	0034586	"	"			
4	0024280	"	"			
5	0023649	"	"			
6	0024632	"	"			
<u>Semi hall Dakin</u>						
1	0024947	MAR	Service			
2	0024946	2024	"			
3	0023649	"	"			
4	0024594	"	"			

Principal
 Army College of Nursing
 Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
 Prof-cum-Principal
 Ph : 82838-24167
 E-mail : acn@awesindia.edu.in

Army College of Nursing
 Deep Nagar
 Jalandhar Cantt-144005

MAINTENANCE RECORD - AIR CONDITIONERS

MAR		- 2024		- 2025			
SNO	A/c SNO	Date of Service	Repair / Service	Next due	Remarks		
5.	CO2- 8541	"	"	↓	Repair →		
6	CO2- 3960	"	"				
7	CO2- 4302	"	"				
8	CO2- 3645	"	"				
<u>Canteen hall A/c</u>							
1	CO-1-4786	MAR 2024	Service	↓	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt		
2	CO-1-4711	2024	"				
<u>Principal office A/c</u>							
1	CO-2-0884		Gas filling & Servicing	↓	Bluf		
2	CO-5-802		Service				
<u>Visitor Room A/c</u>							
1	CO-1-9698		Service	↓	Bluf		
<u>Registrar office A/c</u>							
1	CO-6-7181		Service				
<u>AccT office A/c</u>							
1	4501779		Service	↑	Bluf		
<u>Main office</u>							
1	4501779 Voltage		Starter fitting - D Servicing	↑	Bluf		
2	LSAIBSI RASVAR 32 CAVI eg. old		GAS filling & Servicing				

Principal
 Army College of Nursing
 Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
Prof-cum-Principal
Ph : 82838-24167
E-mail : acn@awesindia.edu.in

Army College of Nursing
Deep Nagar
Jalandhar Cantt-144005

MAINTENANCE RECORD - AIR CONDITIONERS

SIND	A/C SIND	Date of service	Repair/Service	Next due	Remarks
<u>Leet-I</u>					
1	Blue Star New		Serviceing		
2	Window AC 2.5 Ton X	Condem	Serviceing New AC 1.5 Ton - 2024		
<u>Leet-II</u>					
1	Blue star new		Serviceing		
2	Window AC		"		
<u>HOD office</u>					
1	Blue star 1 Ton		Serviceing		
2	"		"		
3	"		"		
4	"		"		
5	"		"		
6	"		"		
<u>CL ROOM Dakin 2.5 Ton</u>					
1	Dakin 2.5 Ton		Serviceing		
2	"		"		
3	"		"		
4	"		"		
5	"		"		
6	"		"		
7	"		"		
8	"		"		
<u>Examination Hall- I</u>					
1	AC - 0.7 2.5 Ton (Level)				

Principal
Army College of Nursing
Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
 Prof-cum-Principal
 Ph : 82838-24167
 E-mail : acn@awesindia.edu.in

Army College of Nursing
 Deep Nagar
 Jalandhar Cantt-144005

MAINTENANCE RECORD - AIR CONDITIONERS

S/NO	A/C S/NO	Date of Service	Repair / Service	Material	E/S	Remarks
<u>Dormo hall - I</u>						
1	706NVT021973		Service			Repair → Joddi - 6x900 = 5400 GAS - 4x1900 = 7600 Capex coil - 1x6500 = 6500 PCB - 2x2800 = 5600 Capacitor - 2x1250 = 2500 Total Amt - 27600/-
2	Blue star		"		Bhl	
<u>Principal Resi</u>						
1	20.S-6610		Power control unit repair & Service			AC Servicing → C - 26x1600 = 41600 B - 34x375 = 12750 W - 2x550 = 550 Total Amt. 54900 + 27600 82500/-
2	20.C-4067		Service		Bhl	
<u>Gym A/C Voltas</u>						
1	15517PIA146009985		Two stainer fitting - ②			Total Amt. 54900 + 27600 82500/-
2	45517HA146009987		Gas filling & Service		Bhl	
<u>T.V Room</u>						
1	514K02301927		Service - voltas			VRY → 4x8000 = 32000/- GAS filling - 12x1500 = 18000/- Labour charge - 1x2500 = 2500/- C.G.S.T @ 9% = 4725/- S.G.S.T @ 9% = 4725/- 61,950.00
2	608P972004883		Power control unit Repair LG old Capex Coil New fitting & Condenser		Bhl	
<u>Lib HOSTEL</u>						
1	45516SYA149001597		Two stainer fitting - ②			VRY → 4x8000 = 32000/- GAS filling - 12x1500 = 18000/- Labour charge - 1x2500 = 2500/- C.G.S.T @ 9% = 4725/- S.G.S.T @ 9% = 4725/- 61,950.00
2	608P972005024		Service voltas		Bhl	
<u>Guest Room - 121</u>						
1	14K0213201647		Stainer fitting - ②			VRY → 4x8000 = 32000/- GAS filling - 12x1500 = 18000/- Labour charge - 1x2500 = 2500/- C.G.S.T @ 9% = 4725/- S.G.S.T @ 9% = 4725/- 61,950.00
			Gas filling & Service		Bhl	
<u>Office Supt</u>						
1	BI-1A318P		Free Service by Blue star			VRY → 4x8000 = 32000/- GAS filling - 12x1500 = 18000/- Labour charge - 1x2500 = 2500/- C.G.S.T @ 9% = 4725/- S.G.S.T @ 9% = 4725/- 61,950.00
	NUDVA08146		E/S office + store keeper Purchase on 15 June-24			
1	VOLTASAC					VRY → 4x8000 = 32000/- GAS filling - 12x1500 = 18000/- Labour charge - 1x2500 = 2500/- C.G.S.T @ 9% = 4725/- S.G.S.T @ 9% = 4725/- 61,950.00
2	"					

Col (Retd)
 Registrar
 Army College of Nursing
 Jalandhar Cantt

Principal
 Army College of Nursing
 Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
 Prof-cum-Principal
 Ph : 82838-24167
 E-mail : acn@awesindia.edu.in

Army College of Nursing
 Deep Nagar
 Jalandhar Cantt-144005

MAINTENANCE RECORD – FIRE EXTINGUISHERS (CYLINDERS)

Fire Extinguishers				Services			
SINO	DT of Service	Location	NO of Cyls	Refilling / Repair	Next due	GIS	Remarks
①	10 Feb 2024 Feb 2024	Hostel & College	CO ₂ type	30x430=12900/-	↓ Next due - Feb 2025 ↑	Blf	 Col (Retd) Registrar Army College of Nursing Jalandhar Cantt
			4.5 kg				
			Foam type	700x27=18900/-			
			09 ltrs				
			ABC dry Pdr	27x580=15660/-			
5kg to 6kg							
			GST 9%	4271.40			
			S&ST 9%	4271.40			
				<u>56002.80/-</u>			
②	20 Pcs	New Pipe & Horn, CO ₂ type, Foam type		350x20=7000/-			
		Fire Exting. Hostl & pip set					
③		New CO ₂ type fire Extinguisher Safety chain set complete		70x20 1400/-		Blf	
④		New valve set fire Extinguisher & gate complete		350x9=3150/-			 Col (Retd) Registrar Army College of Nursing Jalandhar Cantt
				<u>11550/-</u>			
			CGST 9%	1039.50			
			S&ST 9%	1039.50			
				<u>13629/-</u>			

Principal
 Army College of Nursing
 Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
 Prof-cum-Principal
 Ph : 82838-24167
 E-mail : acn@awesindia.edu.in

Army College of Nursing
 Deep Nagar
 Jalandhar Cantt-144005

MAINTENANCE RECORD – LIFT / ELEVATOR

S/No	Make & Type	Type of Service	Dt of Service	Nature of Service	Next Dt	Campy Kap	E/S	Remarks
06	Escan Pvt LTD	Monthly	05 Aug 23	check all landing door panel, Lubricant & Gen checking	Sep 23	Sandeep	Bhp	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt
07	Escan Pvt Ltd	Monthly	22 Aug 23	check all landing door panel, Lubricant & Gen Check up	Oct 23	Sandeep	Bhp	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt
08	Escan Pvt LTD	Monthly	25 Sep 23	check all landing door panel, Lubricant & Gen checkup	Nov 23	Sandeep Kumar	Bhp	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt
09	Escan Pvt Ltd	Monthly / Break Down	05 Oct 23	Landing door Stopper replace 3x floor, check all Gen Maint & Lubrication Etc	Nov 23	Sandeep Kumar	Bhp	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt
10	Escan Pvt Ltd	Monthly / Break Down	20 Nov 23	Check all Landing door Lubrication & Gen checking	Dec 20 23	Sandeep Kumar	Bhp	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt
11	Escan Pvt Ltd	Monthly / Service	22 Dec 23	Check all Lubricant door & landing door or Gen maintenance	JAN 24	Sandeep Kumar	Bhp	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt
12	Escan Pvt Ltd	Monthly / Service	29/1/24	Check all landing door Lubricant or Gen	Feb 24	Sandeep Kumar	Bhp	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt

Principal
 Army College of Nursing
 Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
 Prof-cum-Principal
 Ph : 82838-24167
 E-mail : acn@awesindia.edu.in

Army College of Nursing
 Deep Nagar
 Jalandhar Cantt-144005

MAINTENANCE RECORD – LIFT / ELEVATOR

S.No	Make/Type	Type of Service	Dt. of Service	Nature of Service	Next due	By Rap	C/E	Remarks
14	Escor Pvt LTD	monthly Service	27/3/24	check all landing doors lubrication & Gen maint	Apr-2024	27/3/24	Bsh	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt.
AMC Start wef - Apr 24 To Mar 2025 Amt - Rs - 90500/-								
15	Escor Pvt LTD	monthly Service	23/4/24	check all landing doors, Lubrication & Gen check.	May-2024	23/4/24	Bsh	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt.
16	Escor Pvt Ltd	Monthly Service	20/05/24	Check all Landing doors Lubrication and Gen checkup	Jun 2024	20/5/24	Bsh	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt.
17	Escor Pvt Ltd	Monthly Service	15/06/24	Check all Landing doors Lubrication & Gen Checkup and Sensor cleaning	Jul 2024	15/6/24	Bsh	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt.
18	Escor Pvt LTD	monthly Service	12/7/24	check all landing doors, Lubrication, Gen Check up, sensors & belts	Aug 24	12/7/24	Bsh	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt.
19	Escor Pvt LTD	monthly Service	13-8-24	Check all landing doors Lubrication, Gen maint checkup, sensor, & belt	Sep-24	13/8/24	Bsh	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt.
20	Escor Pvt LTD	lift Repair	22-8-24	lift Repair on P-G card, in-coder card. lift is running & monthly service on.	22/8/24 Repair	22/8/24	Bsh	Col (Retd) Registrar Army College of Nursing Jalandhar Cantt.

Principal
 Army College of Nursing
 Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
 Prof-cum-Principal
 Ph : 82838-24167
 E-mail : acn@awesindia.edu.in

Army College of Nursing
 Deep Nagar
 Jalandhar Cantt-144005

MAINTENANCE RECORD – ANTI MOSQUITO SPRAY

SER NO	DATE & TIME	AREA SPRAYED	PARTICULAR OF SHO REPS	SIG OF SHO REP	SIG OF COLLEGE REP	REMARKS
31	5/6/23 09:00 hrs.	College - All w/rooms w/points, Nut Lab offices, stairs, Reception M.P Hall, Semi hall → outer hall.	Mr Mondal	[Signature]	[Signature]	
		Hostel - All w/rooms Bathrooms, living room Gallory, infirmary Dining hall, Souter area.	Mrs Rita	[Signature]	[Signature]	
					Col (Retd) Registrar Army College of Nursing Jalandhar Cantt	
32	7/6/23 09:00 hrs.	College - All w/rooms Nut Lab w/points offices, m.p hall semi hall, Reception stairs → outer area.	Mr Mondal	[Signature]	[Signature]	
		Hostel -> All student living room, Gallory Bathrooms, Dining hall Q.v Room, Lib. Gym, Quat room → outer area.	Mrs Rita	[Signature]	[Signature]	
					Col (Retd) Registrar Army College of Nursing Jalandhar Cantt	
33	12/7/23 09:00 hrs.	College - All w/rooms Nut Lab w/point offices, m.p hall semi hall Reception stairs & outer.	Mr Mondal	[Signature]	[Signature]	
		Hostel -> All w/rooms Bathrooms, Gallory Q.v Room, Gym, D. Gifroom Dining hall & outer area.	Mrs Pooja	[Signature]	[Signature]	
					Col (Retd) Registrar Army College of Nursing Jalandhar Cantt	
34	10/8/23 09:00 hrs.	College - All w/rooms Nut Lab, w/point offices, m.p hall semi hall reception, stairs & outer area.	Mr Mondal	[Signature]	[Signature]	
		Hostel -> All w/rooms Bathrooms, Gallory, Q.v Room, Dining hall & outer areas.	Mrs Sustha	[Signature]	[Signature]	
					Col (Retd) Registrar Army College of Nursing Jalandhar Cantt	

Principal
 Army College of Nursing
 Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
 Prof-cum-Principal
 Ph : 82838-24167
 E-mail : acn@awesindia.edu.in

Army College of Nursing
 Deep Nagar
 Jalandhar Cantt-144005

RECORD – ANTI MOSQUITO SPRAY

SER NO	DATE & TIME	AREA SPRAYED	SIGNATURE OF SHO REP	SIGNATURE OF COLLEGE REP	REMARKS
34	8/9/23 09:20 hrs	College - All w/rooms water points, reception offices, MP hall, Semi hall, nat lab & outer area. Hostel -> All w/rooms lounge gallery, Dining hall, Gym & outer area.	Mr. Muket Singh	[Signature]	
35	9/10/23 09:45 hrs	College - All w/rooms water points, reception offices, MP hall, Semi hall, nat labs & outer area. Hostel -> All hostel lounge, washrooms, Anita gallery, Gym, Dining hall & outer areas. Principal Resi	Mr. Muket Singh	[Signature]	
36	4/11/23 07:45 hrs	College - All w/rooms water points, reception lib, MP hall, semi hall stairs, nat lab & outer area. Hostel - All hostel lounge, w/rooms, gallery Gym - Dining hall & outer area, Cafe w/rooms & out side, nat Resi.	Mr. Muket Singh	[Signature]	
37	5/11/23 09:00 hrs	College -> All w/rooms water points, reception lib, MP hall, Semi hall lounge, offices, Nat lab & outer area. Hostel -> All hostel w/rooms, Dining hall, Cafe stairs &	Mr. Muket Singh	[Signature]	

[Signature]
 Principal
 Army College of Nursing
 Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
 Prof-cum-Principal
 Ph : 82838-24167
 E-mail : acn@awesindia.edu.in

Army College of Nursing
 Deep Nagar
 Jalandhar Cantt-144005

RECORD – ANTI MOSQUITO SPRAY

ANTI MOSQUITO SPRAY : RECORD REGISTER					ANTI MOSQUITO SPRAY : RECORD REGISTER							
DATE & TIME	AREA SPRAYED	PARTICULAR OF SHO. REPS	SIG OF SHO REP	SIG OF COLLEGE REP	REMARKS	SER NO	DATE & TIME	AREA SPRAYED	PARTICULAR OF SHO REPS	SIG OF SHO REP	SIG OF COLLEGE REP	REMARKS
(b)	(c)	(d)	(e)	(f)	(g)							
<u>Mosquito spray As on 02 JAN 2024</u>						<u>Mosquito spray as on 5/3/24</u>						
JAN 24 09:00 AM	College → All w/room water points, MP hall beam hall Null lab & outer area Hostel → All hostel pantries, w/room gallery, Dining hall, infirmary, Gym, G/Room & outer area.	Mr Mohan Mrs Rita	<i>[Signature]</i> <i>[Signature]</i>	<i>[Signature]</i> <i>[Signature]</i>	<i>[Signature]</i> Col (Retd) Registrar Army College of Nursing Jalandhar Cantt	40	5 MAR 24 09:00 AM	Hostel → All w/room pantries, water points Dining hall, infirmary visiting room & outer area. college → All w/room water points, stair reception, Seminar hall m.p hall & outer area Principal Resi.	Mr Muket Mrs Anita	<i>[Signature]</i> <i>[Signature]</i>	<i>[Signature]</i> <i>[Signature]</i>	<i>[Signature]</i> Col (Retd) Registrar Army College of Nursing Jalandhar Cantt
<u>Mosquito spray as on 05 Feb 24</u>												
MAR 24 09:00 AM	Hostel → All pantries water points, w/room Gallery, Dining hall visiting room, infirmary Gym, G/Room & outer area College → All w/room Null lab, MP hall beam hall, reception lectures both sides w/pantry & outer area. Principal Resi.	Mr Mohan Mrs Rita	<i>[Signature]</i> <i>[Signature]</i>	<i>[Signature]</i> <i>[Signature]</i>	<i>[Signature]</i> Col (Retd) Registrar Army College of Nursing Jalandhar Cantt	41	06 APR 24 09:00 AM	Hostel → All w/room pantries, water points G/Room, infirmary visiting room, Dining hall & outer area College → All w/room water point reception Mes stair, Seminar hall conf hall, offices m.p hall & outer area.	Mr Mohan Mrs Anita	<i>[Signature]</i> <i>[Signature]</i>	<i>[Signature]</i> <i>[Signature]</i>	<i>[Signature]</i> Col (Retd) Registrar Army College of Nursing Jalandhar Cantt

[Signature]

Principal
 Army College of Nursing
 Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
 Prof-cum-Principal
 Ph : 82838-24167
 E-mail : acn@awesindia.edu.in

Army College of Nursing
 Deep Nagar
 Jalandhar Cantt-144005

RECORD – ANTI MOSQUITO SPRAY

SER NO	DATE & TIME	AREA SPRAYED	PARTICULAR OF SHO REPS	SIG OF SHO REP	SIG OF COLLEGE REP	REMARKS
<u>Mosquito spray as on: 06/5/24</u>						
42	06 May 24 09:00 AM	College - All w/rooms water points, reception stairs, MP hall, semi hall, canteen hall, NUT lab & outer area. Hostel -> all pantries w/rooms stairs 7-V Room, Gym, infirmary Dining hall, & outer area.	Mr Muket Hori Mrs Shyam Devi	<i>[Signature]</i> <i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i> Col (Retd) Registrar Army College of Nursing Jalandhar Cantt
<u>Lizard spray as on: 29/6/24</u>						
44	29/6/24 09:00 AM	College Hostel -> All w/rooms Dining hall, gallery renting stair, visiting rooms, & outside Room hostel 7-V Ms. Sunita Room, Gym, & lab.	Mr Muket Hori Mrs Ms. Sunita	<i>[Signature]</i> <i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i> Col (Retd) Registrar Army College of Nursing Jalandhar Cantt
<u>Mosquito spray as on: 13/6/24</u>						
43	Jun-24 09:00 AM	College - All pantries, water stairs, semi hall MP hall, canteen hall NUT lab & outer area. Hostel All pantries, w/rooms 7-V room Gym infirmary, Dining hall, G/room & outer area.	Mr Muket Hori Mrs Shyam Devi Pari	<i>[Signature]</i> <i>[Signature]</i> <i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i> Col (Retd) Registrar Army College of Nursing Jalandhar Cantt
<u>Mosquito spray as on: 06/7/2024</u>						
45	6/7/24 09:00 AM	College -> All w/rooms pantries, water pantry, stairs, MP hall semi hall, reception NUT lab, & outer area. Hostel -> All w/rooms pantries, dining hall Infirmary, 7-V Room lab, gym & outer area.	Mr. Manu Mrs. Pooja	<i>[Signature]</i> <i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i> Col (Retd) Registrar Army College of Nursing Jalandhar Cantt

[Signature]

Principal
 Army College of Nursing
 Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
Prof-cum-Principal
Ph : 82838-24167
E-mail : acn@awesindia.edu.in

Army College of Nursing
Deep Nagar
Jalandhar Cantt-144005

RECORD – ANTI MOSQUITO SPRAY

SER NO	DATE & TIME	ARE SPRAYED	PARTICULAR OF SHO REPS	SIG OF SHO REP	SIG OF COLLEGE REP	REMARKS
<u>Mosquito spray as on-06/08/24</u>						
46	Aug 24	College → All w/room 09:00 AM	W/ Paint, Parties , Stairs, office, m/h hall, Semi hall, Nut Lab & outer area	MR Mukat Jain	[Signature]	
		Hostel → All w/room	Parties, Gallery Infermary, Dining hall, P.V Room, Gym Lib. visitor Room & outer area.	Mrs Patti	[Signature]	
				Col (Retd) Registrar Army College of Nursing Jalandhar Cantt	[Signature]	
<u>Mosquito spray as on-05/9/2024</u>						
47	Sep 24	College → All w/room 09:00 AM	Parties, Stairs, w/Parties offices, Semi hall, m/hall con hall, Nut Lab, & outer area.	MR Mohan	[Signature]	
		Hostel → All w/room	Parties, Gallery Infermary, Dining hall, T.V Room, Gym Lib. visitor Room & outer area.	Mrs Doga	[Signature]	
				Col (Retd) Registrar Army College of Nursing Jalandhar Cantt	[Signature]	

Principal
Army College of Nursing
Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
 Prof-cum-Principal
 Ph : 82838-24167
 E-mail : acn@awesindia.edu.in

Army College of Nursing
 Deep Nagar
 Jalandhar Cantt-144005

RECORD – CLEANING OF WATER COOLERS

Water cooler cleaned on 19/6/24						Water cooler cleaned on 29/7/24							
S.No	Location	Qty	Cleaned on	Hostel No./Floor	Warden	S/S	S.No	Location	Qty	Cleaned on	Hostel No./Floor	Warden	S/S
1	Hostel	-					1	Hostel	-				
	1st Floor	-						1st Floor	-				
	221, 227	02			M.H.D	Prof		221, 227	02			Prof	Prof
2	2nd Floor	-					2	2nd Floor	-				
	321, 327	02						321, 327	02				
3	3rd Floor	-					3	3rd Floor	-				
	429, 430	02						429, 430	02				
4	Dinning hall	01					4	Dinning hall	01				
	College	-						College	-				
1	NUT Lab	01					1	NUT Lab	01				
2	Fmn Lab	01					2	Fmn Lab	01				
3	Comp Lab	01					3	Comp Lab	01				
4	Reads Lab	01					4	Reads Lab	01				
Col (Retd) Registrar Army College of Nursing Jalandhar Cantt						Col (Retd) Registrar Army College of Nursing Jalandhar Cantt							
Water cooler cleaned on 06/7/2024						Water cooler cleaned on 05/08/24							
1	Hostel	-					1	Hostel	-				
	1st Floor	-						1st Floor	-				
	221, 227	02						221, 227	02				
2	2nd Floor	-					2	2nd Floor	-				
	321, 327	02						321, 327	02				
3	3rd Floor	-					3	3rd Floor	-				
	429, 430	02						429, 430	02				
4	Dinning hall	01					4	Dinning hall	01				
	College	-						College	-				
1	NUT Lab	01					1	NUT Lab	01				
2	Fmn Lab	01					2	Fmn Lab	01				
3	Comp Lab	01					3	Comp Lab	01				
4	Reads Lab	01					4	Reads Lab	01				
Col (Retd) Registrar Army College of Nursing Jalandhar Cantt						Col (Retd) Registrar Army College of Nursing Jalandhar Cantt							

Principal
 Army College of Nursing
 Jalandhar Cantt




Prof (Dr) Vadivukkarasi P
 Prof-cum-Principal
 Ph : 82838-24167
 E-mail : acn@awesindia.edu.in

Army College of Nursing
 Deep Nagar
 Jalandhar Cantt-144005

RECORD – CLEANING OF WATER COOLERS

S.No	Location	Qty	Cleaned on	Next due	Hostel Incharge	Warden	A/S	Remarks
<u>Water cooler cleaned on-21/8/2024</u>								
1	Hostel	-						
	1st Floor	-						
	221, 227	02						
2	2nd Floor	-						
	321, 327	02						
3	3rd Floor	-						
	429, 430	02						
4	Dining hall	-						
	College	-						
1	Nut Lab	01						
2	Farm Lab	01						
3	Camp Lab	01						
4	Peachs Lab	01						
<u>Water cooler cleaned on-08/9/24</u>								
1	Hostel	-						
	1st Floor	-						
	221, 227	02						
2	2nd Floor	-						
	321, 327	02						
3	3rd Floor	-						
	429, 430	02						
4	Dining hall	01						
	College	-						
1	Nut Lab	01						
2	Farm Lab	01						
3	Camp Lab	01						
4	Peachs Lab	01						

S.No	Location	Qty	Cleaned on	Next due	Hostel Incharge	Warden	A/S	Remarks
<u>Water cooler/Tank cleaned on-10/11/24</u>								
Under ground water tank cleaned on-10/11/2024								
Near service centre.								
Tanks Qty-02 80,000 ltr each tank								
Next due- Feb-2024								
Total Amt → 15104/-								
<u>11/9/24</u>								
<u>HOSTEL</u>								
1	1st Floor	02						
	221, 227	02						
2	2nd Floor	-						
	321, 327	02						
3	3rd Floor	-						
	429, 430	02						
4	Dining hall	01						
	College	-						
1	Nut Lab	01						
2	Farm Lab	01						
3	Camp Lab	01						
4	Peachs Lab	01						


 Principal
 Army College of Nursing
 Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
Prof-cum-Principal
Ph : 82838-24167
E-mail : acn@awesindia.edu.in

Army College of Nursing
Deep Nagar
Jalandhar Cantt-144005

RECORD – CLEANING OF RO WATER PURIFIER (HOSTEL)

19/9/24

S/NO	Location	Qty	Cleaned on	Next due	Hostel incharge	Warden
1	New RO	Total	carve	day	filling on	19/9/24
Capacity - 25 Ltrs per hours supply.						
D. Complab, Fmn lab, Nut lab, Peach lab.						
Service every 6 Month.						
Amount - Rs -						

Principal
Army College of Nursing
Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
Prof-cum-Principal
Ph : 82838-24167
E-mail : acn@awesindia.edu.in

Army College of Nursing
Deep Nagar
Jalandhar Cantt-144005

SERVICE RECORD – CLEANING OF RO PLANT

(Reverse Osmosis Plants)

RO PLANT NEW INSTALLED ON- APR-2024.

S.No	Nomenclature	Location	Ltrs	Work Done	DT of Serv	Next Date	Hostel/Incharge	Warden	ELS	Remarks
1	RO Plant	HOSTEL B wing Top.	256lts	New fitting	Apr 2024	Sep-2024	M/S	Dr. S.	Blk	RO - 177000 Std - 23600 T.K - 11500 Pipe line - 45000 Total - 257100

Col (Retd)
Registrar
Army College of Nursing,
Jalandhar Cantt

Principal
Army College of Nursing
Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
Prof-cum-Principal
Ph : 82838-24167
E-mail : acn@awesindia.edu.in

Army College of Nursing
Deep Nagar
Jalandhar Cantt-144005

RECORD – CLEANING OF WATER PURIFIERS

ACNA GD Servicing on 1 Dec 2023

S.No	Nomenclature	Qty	Brand/Model	Work done	Signature	Verified	Warden	Q/s	Remarks
1	Aqua.gd Diang hall	150 ltrs	"	New filters 3+1 pcs	DEC-2023	JAN-2024	[Signature]	[Signature]	Rs. 10349/-
2	Voltage cooler 221 'A' wing	180 ltrs	Aqua fresh	"					
3	Aqua.gd.canteen 227 'A' wing	80 ltrs	"	"					
4	Voltage cooler 321 'A' wing	40 ltrs	"	"					
5	Voltage cooler 327 'B' wing	80 ltrs	"	"					
6	Voltage cooler 427 'A' wing	80 ltrs	"	"					
7	Aqua.gd. 850 'A' wing	80 ltrs	"	"					
1	Aqua.Gd Nut Lab	80 ltrs	"	3+1 pcs	DEC-2023	JAN-2024	[Signature]	[Signature]	Rs. 5605/-
2	Voltage cooler Fm Lab	80 ltrs	"	"					
3	Voltage cooler Camp Lab	20 ltrs	"	"					
4	Voltage Lab. Canteen	80 ltrs	"	"					
5	Water Purifier Nut Lab	20 ltrs	"	"					

Col (Retd)
 Registrar
 Army College of Nursing
 Jalandhar Cantt

Principal
Army College of Nursing
Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
Prof-cum-Principal
Ph : 82838-24167
E-mail : acn@awesindia.edu.in

Army College of Nursing
Deep Nagar
Jalandhar Cantt-144005

RECORD – ELECTRICAL PANEL SERVICE

Sr No	make & type of Panel	Service Done	Date of service	Work done	Material	Rate	Remarks
12	Elect Panel Service		11/3/2024	I VCB Service - ③ - 11,800.00 with GSP II A.C.S Service ② - 7080.00 with GSP III indicators ⑧ 1416.00 Total Amt - 20,296.00	Mazda - 24	ms	By Col (Retd) Registrar Army College of Nursing Jalandhar Cantt

Principal
Army College of Nursing
Jalandhar Cantt



Prof (Dr) Vadivukkarasi P
Prof-cum-Principal
Ph : 82838-24167
E-mail : acn@awesindia.edu.in

Army College of Nursing
Deep Nagar
Jalandhar Cantt-144005

MAINTENANCE RECORD – FLOOR CLEANING EQUIPMENT

<u>EUREKA FORBES Mopper</u>				<u>Cleaning Machine</u>			
Srno	Make/Type	Service time	Details Service	Next due	EIS	Registration	Remarks
616000565	Abila 50E Ptno- 104566	1425'	EUREKA FORBES	Aug 2017			
2500518	Brush user Guide	"	EURO STEAM				
415003926	MEGA 43	"	Single Disk Scrubber				

Col (Dr) Registrar
Army College of Nursing
Jalandhar Cantt

Principal
Army College of Nursing
Jalandhar Cantt